AI Tech International Journal, **ISSN: 3079-4749**
Vol. 4, No. 1, January-June, 2026,
Journal homepage: https://techaijournal.com

Multi-Objective Optimization of Electric Vehicle Charging Schedules in Distribution Networks

Oliver Whitcombe

Dept. of Electrical and Electronic Engineering, Northvale University, United Kingdom

Article Info

Article history:
Received December 29, 2026
Revised January 14, 2026
Accepted February 09, 2026
Published March 07, 2026

Keywords: Electric Vehicle (EV) Charging Optimization, Multi-Objective Optimization, Distribution Network Management, Smart Charging and Vehicle-to-Grid (V2G), Renewable Energy Integration

ABSTRACT

The rapid adoption of electric vehicles (EVs) has significantly increased electricity demand and introduced new challenges for the operation, planning, and stability of electrical distribution networks. Uncoordinated EV charging can lead to peak load escalation, voltage fluctuations, transformer overloading, increased power losses, and higher electricity costs. To address these challenges, multi-objective optimization has emerged as an effective approach for developing intelligent and coordinated EV charging strategies that balance technical, economic, and environmental requirements. This study investigates multi-objective optimization techniques for scheduling electric vehicle charging in distribution networks while considering charging demand, grid operational constraints, electricity pricing, renewable energy integration, and consumer convenience. The proposed framework aims to simultaneously minimize electricity generation and charging costs, reduce distribution network power losses, improve voltage stability, and minimize peak load demand. Advanced optimization algorithms, including Genetic Algorithms (GA), Particle Swarm Optimization (PSO), Multi-Objective Particle Swarm Optimization (MOPSO), and Non-Dominated Sorting Genetic Algorithm II (NSGA-II), are considered for identifying optimal charging schedules under different operating conditions. The methodology incorporates EV battery characteristics, charging station capacities, time-of-use electricity tariffs, distribution network constraints, and renewable energy availability. Furthermore, smart charging and Vehicle-to-Grid (V2G) strategies are explored to improve load flexibility and facilitate efficient utilization of renewable energy resources.

The effectiveness of the proposed optimization framework can be evaluated through simulation studies using standard distribution network test systems, considering performance indicators such as peak demand reduction, voltage deviation, power losses, charging costs, and computational efficiency. The expected outcomes highlight the potential of coordinated EV charging to improve distribution network reliability, reduce operational expenses, and support sustainable transportation and energy systems. However, uncertainties associated with EV arrival and departure times, battery state of charge, user preferences, electricity prices, and renewable energy generation remain important research challenges. Overall, multi-objective optimization of EV charging schedules provides a promising framework for developing intelligent, economical, reliable, and environmentally sustainable distribution networks.

This is an open access article under the CC BY-SA license.

AI Tech International Journal, **ISSN: 3079-4749**
Vol. 4, No. 1, January-June, 2026,
Journal homepage: https://techaijournal.com

INTRODUCTION

The rapid development of electric vehicle (EV) technology has transformed the global transportation sector by providing an environmentally sustainable alternative to conventional internal combustion engine vehicles. Increasing concerns regarding greenhouse gas emissions, fossil fuel depletion, air pollution, and energy security have encouraged governments, industries, and consumers to adopt electric mobility. Technological advancements in battery systems, charging infrastructure, power electronics, and renewable energy integration have further accelerated EV adoption. However, the growing penetration of electric vehicles introduces significant challenges for existing electrical distribution networks, particularly in terms of electricity demand management, voltage stability, peak load control, and network operational efficiency.

Electric vehicles require regular battery charging, which creates additional electrical loads on distribution systems. When a large number of EVs are charged simultaneously without proper coordination, the resulting demand can increase peak loading, cause transformer overloading, increase power losses, and produce voltage deviations. These problems become more significant in residential and commercial distribution networks where charging activities may occur during conventional peak electricity consumption periods. Therefore, developing effective EV charging schedules is essential for maintaining reliable distribution network operation while satisfying the energy requirements of EV users.

Multi-objective optimization has emerged as an important computational approach for addressing the complex challenges associated with EV charging management. Unlike conventional optimization methods that focus on a single objective, multi-objective optimization simultaneously considers several conflicting objectives, including minimizing electricity costs, reducing network power losses, maintaining voltage stability, lowering peak demand, and improving consumer satisfaction. Achieving an appropriate balance among these objectives can support efficient electricity utilization and improve the overall performance of distribution networks.

THEORETICAL FRAMEWORK

1. Introduction to the Theoretical Framework

The theoretical framework establishes the fundamental concepts, mathematical principles, optimization techniques, and electrical network characteristics associated with electric vehicle (EV) charging schedule optimization. The increasing penetration of EVs into electrical distribution networks requires intelligent charging strategies to maintain network stability, reduce operational costs, minimize power losses, and improve energy utilization.

The proposed framework integrates multi-objective optimization, smart charging, load management, renewable energy integration, and Vehicle-to-Grid (V2G) technology. It provides a theoretical foundation for developing coordinated EV charging schedules that balance the requirements of electricity distribution operators and EV consumers.

2. Electric Vehicle Charging Characteristics

Electric vehicles operate using rechargeable battery systems that require electricity from charging stations. The charging demand depends on several factors, including battery capacity, State of Charge (SoC), charging power, arrival time, departure time, and user energy requirements.

The energy required by an electric vehicle can be expressed as:

$$E_{EV} = C_b(SOC_{target} - SOC_{initial})$$

Where:

- E_{EV} = Required charging energy.
- C_b = Battery capacity.
- SOC_{target} = Desired battery state of charge.
- $SOC_{initial}$ = Initial battery state of charge.

The charging time can be estimated as:

$$T_c = \frac{E_{EV}}{P_c \eta_c}$$

Where:

- T_c = Charging duration.
- P_c = Charging power.
- η_c = Charging efficiency.

These parameters are essential for determining suitable charging schedules while satisfying individual vehicle requirements.

3. Multi-Objective Optimization Theory

Multi-objective optimization involves simultaneously optimizing multiple conflicting objectives within a given system. In EV charging management, the primary objectives generally include:

1. Minimization of electricity charging costs.
2. Reduction of distribution network power losses.
3. Minimization of peak electricity demand.
4. Improvement of voltage stability.
5. Maximization of renewable energy utilization.
6. Enhancement of consumer charging convenience.

The general mathematical formulation is:

$$\min F(x) = [f_1(x), f_2(x), f_3(x), \ldots, f_n(x)]$$

Subject to:

$$g_i(x) \leq 0$$

$$h_j(x) = 0$$

Where:

- $F(x)$ represents the multi-objective optimization function.
- $f_i(x)$ represents individual optimization objectives.
- $g_i(x)$ represents inequality constraints.
- $h_j(x)$ represents equality constraints.
- x represents the decision variables, including EV charging schedules.

The optimization process identifies Pareto-optimal solutions, which represent different trade-offs among competing objectives.

4. Electricity Charging Cost Minimization

Electricity charging cost is one of the most important economic objectives in EV charging schedule optimization. Electricity tariffs generally vary throughout the day according to demand and supply conditions.

The total charging cost can be expressed as:

$$\min F_1 = \sum_{t=1}^{T} \pi_t P_{EV}(t) \Delta t$$

Where:

- π_t = Electricity price during time interval t.
- $P_{EV}(t)$ = Total EV charging power.
- Δt = Time interval.
- T = Total scheduling period.

Time-of-use pricing encourages EV owners to charge vehicles during low-cost electricity periods, reducing overall charging expenses and helping shift demand away from peak hours.

PROPOSED MODELS AND METHODOLOGIES

1. Proposed Research Framework

The proposed research develops an intelligent multi-objective optimization framework for scheduling electric vehicle (EV) charging in electrical distribution networks. The primary objective is to coordinate EV charging activities while simultaneously minimizing electricity costs, reducing distribution network power losses, controlling peak demand, and maintaining voltage stability.

The framework integrates EV battery characteristics, charging station capacities, electricity pricing, renewable energy availability, and distribution network operational constraints. Advanced optimization algorithms, including Genetic Algorithm (GA), Particle Swarm Optimization (PSO), Multi-Objective Particle Swarm Optimization (MOPSO), and Non-Dominated Sorting Genetic Algorithm II (NSGA-II), are considered to identify efficient charging schedules.

The proposed methodology consists of the following major stages:

1. EV charging demand modeling.
2. Distribution network modeling.
3. Development of multi-objective functions.
4. Formulation of operational constraints.
5. Implementation of optimization algorithms.
6. Renewable energy and V2G integration.
7. Simulation and comparative performance evaluation.

2. Electric Vehicle Charging Demand Model

The EV charging demand model represents the electricity requirements of individual electric vehicles based on battery capacity, initial State of Charge (SoC), desired SoC, charging efficiency, and arrival and departure times.

The required charging energy is calculated as:

$$E_i = C_i(SOC_i^{target} - SOC_i^{initial})$$

Where:

- E_i = Required charging energy of EV i.
- C_i = Battery capacity.
- SOC_i^{target} = Target battery state of charge.
- $SOC_i^{initial}$ = Initial battery state of charge.

The charging power is constrained by:

$$0 \leq P_{i,t}^{ch} \leq P_i^{max}$$

The battery charging dynamics can be expressed as:


$$SOC_{i,t+1} = SOC_{i,t} + \frac{\eta_i^{ch} P_{i,t}^{ch} \Delta t}{C_i}$$

This model ensures that EV charging schedules satisfy individual battery requirements while preventing excessive charging.

3. Distribution Network Modeling

The distribution network model represents the electrical infrastructure supplying power to residential, commercial, and industrial consumers, including EV charging stations.

The proposed framework considers a standard IEEE 33-bus or IEEE 69-bus distribution test system for simulation and performance evaluation.



The network model includes:

- Distribution buses and transmission lines.
- Transformer capacity and operational limits.
- Voltage magnitude and phase angle.
- Existing electricity demand.
- EV charging station locations.
- Renewable energy generation units.

The power balance equation is represented as:

$$P_{grid,t} + P_{RE,t} = P_{base,t} + P_{EV,t} + P_{loss,t}$$

Where:

- $P_{grid,t}$ = Power supplied by the main grid.
- $P_{RE,t}$ = Renewable energy generation.
- $P_{base,t}$ = Conventional electricity demand.
- $P_{EV,t}$ = Total EV charging demand.
- $P_{loss,t}$ = Distribution network power losses.

An appropriate AC or validated distribution power-flow model will be used to calculate bus voltages, line currents, and network losses.

EXPERIMENTAL STUDY

1. Introduction

The experimental study of "Multi-Objective Optimization of Electric Vehicle Charging Schedules in Distribution Networks" focuses on evaluating the effectiveness of intelligent optimization techniques for coordinating electric vehicle (EV) charging while maintaining the operational stability, reliability, and efficiency of electrical distribution networks. The primary objective is to investigate how optimized charging schedules can reduce electricity costs, minimize power losses, mitigate peak demand, and improve voltage profiles.

The proposed experiments consider different EV penetration levels, charging patterns, electricity tariff structures, renewable energy integration scenarios, and optimization algorithms. Simulation-based analysis can be conducted using MATLAB/Simulink, Python, or other power system optimization platforms.

2. Experimental Objectives

The major objectives of the experimental study are:

1. To evaluate the impact of uncontrolled EV charging on distribution network performance.
2. To minimize total electricity charging costs through optimized scheduling.
3. To reduce active power losses in distribution feeders.
4. To minimize peak demand and avoid network congestion.
5. To improve voltage stability across distribution network buses.
6. To compare the performance of Genetic Algorithm (GA), Particle Swarm Optimization (PSO), Multi-Objective Particle Swarm Optimization (MOPSO), and Non-Dominated Sorting Genetic Algorithm II (NSGA-II).
7. To examine the benefits of integrating renewable energy sources and vehicle-to-grid (V2G) technology.

3. Experimental Setup

A standard IEEE 33-bus or IEEE 69-bus radial distribution test system can be selected to evaluate the proposed optimization framework.

Table 1. Simulation and Experimental Parameters

Parameter	Experimental Configuration
Distribution network	IEEE 33-bus system
Simulation duration	24 hours
Time resolution	30 minutes
Total time intervals	48
EV penetration levels	10%, 20%, 30%, 40%, 50%
EV battery capacity	40–75 kWh
Charging power	3.3–22 kW
Initial state of charge (SoC)	20–60%
Desired departure SoC	80–100%
Optimization algorithms	GA, PSO, MOPSO, NSGA-II
Renewable energy sources	Solar PV and wind
Charging strategies	Uncontrolled, TOU-based, optimized
Network analysis	Load flow and voltage analysis
Programming environment	MATLAB/Python

Note: These are proposed simulation parameters. They should be adjusted according to the selected test feeder, EV dataset, and experimental assumptions.

4. Experimental Scenarios

To examine the performance of the proposed optimization framework, the following experimental scenarios are considered.

Scenario 1: Uncontrolled EV Charging

In this scenario, EVs begin charging immediately after arriving at their respective charging locations. Charging demand is not coordinated with electricity prices or distribution network loading conditions.

The experiment investigates the impact of uncontrolled charging on:

- Peak electricity demand.
- Distribution transformer loading.
- Bus voltage deviations.
- Active power losses.
- Overall network operating efficiency.

Scenario 2: Time-of-Use (TOU)-Based Charging

In this scenario, EV charging is scheduled according to electricity tariff variations. EVs are encouraged to charge during off-peak hours when electricity prices are comparatively lower.

The main objective is to reduce charging expenses while shifting demand away from high-price periods. However, tariff-based scheduling alone may not sufficiently address network voltage and congestion constraints.

Scenario 3: Single-Objective Optimization

In this experiment, individual optimization algorithms are applied to minimize a particular objective, such as:

- Total EV charging cost.
- Active power losses.

- Peak load demand.
- Voltage deviation.

The results help identify the strengths and weaknesses of optimizing each objective independently.

Scenario 4: Multi-Objective Optimization
This scenario applies MOPSO and NSGA-II to optimize multiple objectives simultaneously. The algorithms generate a set of Pareto-optimal charging schedules that represent different trade-offs among economic and technical performance.

The considered objectives include:

1. Minimization of electricity charging costs.
2. Minimization of active power losses.
3. Minimization of peak demand.
4. Minimization of voltage deviation.

The final charging schedule can be selected using a decision-making method such as TOPSIS or a weighted preference approach, depending on the priorities of the distribution system operator.

Scenario 5: Renewable Energy and V2G Integration
This scenario investigates the influence of renewable energy resources and bidirectional EV charging on distribution network performance.

Solar photovoltaic and wind generation are integrated into the distribution system. EVs equipped with V2G capabilities can discharge electricity during peak-demand periods and recharge when demand is low or renewable generation is abundant.

The experiment evaluates:

- Renewable energy utilization.
- Reduction in peak demand.
- Changes in distribution network losses.
- Charging and discharging costs.
- Voltage profile improvements.

RESULTS & ANALYSIS

1. Introduction
The results and analysis of "Multi-Objective Optimization of Electric Vehicle Charging Schedules in Distribution Networks" focus on evaluating the effectiveness of intelligent EV charging strategies in improving the technical and economic performance of electrical distribution systems. The analysis considers the impact of uncontrolled charging, time-of-use (TOU) charging, single-objective optimization, and multi-objective optimization on electricity costs, peak demand, active power losses, and voltage stability.

The proposed evaluation framework considers optimization algorithms such as Genetic Algorithm (GA), Particle Swarm Optimization (PSO), Multi-Objective Particle Swarm Optimization (MOPSO), and Non-Dominated Sorting Genetic Algorithm II (NSGA-II). The performance of these algorithms can be examined using standard IEEE 33-bus and 69-bus distribution networks under different EV penetration levels.

2. Analysis of EV Charging Strategies
Different EV charging strategies produce different effects on distribution network performance.

A. Uncontrolled Charging
Uncontrolled charging may increase electricity demand during evening peak hours because many EV owners connect their vehicles after returning home. This simultaneous charging can increase transformer loading, feeder congestion, and distribution system losses. It may also cause voltage drops at buses located far from the substation.

B. Time-of-Use-Based Charging
TOU-based charging shifts EV charging activities toward periods with lower electricity tariffs. This approach can reduce charging expenses and distribute demand more evenly across the day. However, concentrating charging within the same off-peak period may create a secondary demand peak if charging is not coordinated with network operating conditions.

C. Single-Objective Optimization

Single-objective optimization focuses on improving one specific performance indicator, such as charging cost or active power losses. Although it can provide substantial improvement in the selected objective, it may produce less desirable outcomes for other network parameters.

D. Multi-Objective Optimization
Multi-objective optimization simultaneously considers economic and technical performance indicators. MOPSO and NSGA-II can generate Pareto-optimal solutions that provide different combinations of charging cost, peak demand, power losses, and voltage deviation. This enables distribution system operators to select charging schedules according to their operational priorities.

3. Impact on Peak Load Demand
Peak load demand is an important indicator of distribution network performance. Uncontrolled EV charging can increase the maximum demand, particularly during residential evening hours.

Coordinated charging schedules distribute EV charging demand across available time intervals while considering battery requirements and network constraints. Multi-objective optimization can further reduce peak demand by allocating charging power to periods when sufficient network capacity is available.

4. Analysis of Active Power Losses
Active power losses are influenced by the current flowing through distribution lines and the resistance of network components. As EV charging demand increases, line currents may rise, resulting in higher resistive losses.

The proposed multi-objective framework minimizes active power losses by coordinating charging schedules and avoiding excessive simultaneous charging. Network-aware scheduling can allocate EV demand to time intervals when feeder loading is relatively low.

The effectiveness of the optimization strategy can be evaluated using:

$$P_{\text{loss}} = \sum_{(i,j)\in L} R_{ij}|I_{ij}|^2$$

The comparison should consider:

- Total active power losses before EV integration.
- Losses under uncontrolled charging.
- Losses under TOU-based charging.
- Losses under GA-, PSO-, MOPSO-, and NSGA-II-based scheduling.
- Changes in losses under renewable energy and V2G integration.

COMPARATIVE ANALYSIS IN TABULAR FORM

The comparative analysis of "Multi-Objective Optimization of Electric Vehicle Charging Schedules in Distribution Networks" evaluates different EV charging strategies and optimization algorithms based on their economic, technical, and operational performance. The comparison focuses on charging costs, peak demand, active power losses, voltage stability, renewable energy integration, and overall distribution network efficiency.

1. Comparative Analysis of EV Charging Strategies

Table 1. Comparison of Different EV Charging Strategies

Parameters	**Uncontrolled Charging**	**TOU-Based Charging**	**Single-Objective Optimization**	**Multi-Objective Optimization**
Charging cost	Generally high	Relatively low	Optimized for selected objective	Balanced cost optimization
Peak demand	High	May decrease	Reduced if targeted	Explicitly minimized
Active power losses	May increase significantly	Variable	Reduced if targeted	Considered simultaneously
Voltage stability	May deteriorate	Potential improvement	Depends on objective	Explicitly considered

Load balancing	Poor	Moderate	Good for selected objective	Comprehensive
Renewable integration	Limited coordination	Possible	Depends on formulation	Can be incorporated
V2G compatibility	Limited	Possible	Depends on formulation	Can be optimized
Network congestion	Higher risk	Moderate risk	Depends on constraints	Explicitly addressed
Operational flexibility	Low	Moderate	Moderate	High
Overall performance	Less efficient	Economically beneficial	Objective-dependent	Comprehensive optimization

2. Comparative Analysis of Optimization Algorithms

Table 2. Performance Comparison of Optimization Algorithms

Evaluation Criteria	**Genetic Algorithm (GA)**	**Particle Swarm Optimization (PSO)**	**MOPSO**	**NSGA-II**
Optimization approach	Evolutionary search	Swarm intelligence	Multi-objective swarm intelligence	Multi-objective evolutionary search
Objective handling	Primarily single-objective; can be extended	Primarily single-objective; can be extended	Multiple objectives	Multiple objectives
Convergence behavior	Depends on genetic operators	Often fast initially	Depends on archive and swarm diversity	Depends on population and generation settings
Solution diversity	Population-based	May decrease prematurely	Maintained through external archive	Maintained through crowding distance
Pareto-optimal solutions	Requires multi-objective extension	Requires multi-objective extension	Supported	Supported
Computational complexity	Moderate to high	Moderate	Moderate to high	Moderate to high
Parameter sensitivity	Crossover and mutation rates	Inertia and acceleration coefficients	Swarm and archive parameters	Population and genetic parameters
Suitability for EV scheduling	Good	Good	Very good	Very good

3. Comparative Analysis of Distribution Network Performance

Table 3. Technical Performance Indicators

Performance Indicator	**Uncontrolled Charging**	**TOU-Based Charging**	**MOPSO-Based Scheduling**	**NSGA-II-Based Scheduling**
Peak load demand	Potentially high	Reduced in favorable tariff conditions	Optimized through multiple objectives	Optimized through multiple objectives
Active power losses	May increase	Depends on load shifting	Minimized as an objective	Minimized as an objective
Voltage deviation	May increase	May improve	Minimized as an objective	Minimized as an objective
Transformer loading	Higher risk of overloading	Potentially improved	Managed through constraints	Managed through constraints
Charging expenses	Potentially high	Reduced during low-tariff periods	Balanced against network objectives	Balanced against network objectives
Network reliability	May be affected	Depends on network constraints	Improved if constraints are satisfied	Improved if constraints are satisfied
Scheduling flexibility	Low	Moderate	High	High

Note: The MOPSO and NSGA-II columns describe their intended capabilities when the corresponding objectives and network constraints are included in the optimization model. They do not imply experimentally verified superiority.

4. Comparative Analysis of EV Penetration Levels

Table 4. Influence of EV Penetration on Distribution Networks

EV Penetration Level	Network Loading	Peak Demand Impact	Voltage Profile	Recommended Charging Strategy
10%	Relatively low	Limited impact	Generally manageable	TOU-based charging
20%	Moderate	Increasing demand	Requires monitoring	Coordinated charging
30%	Moderately high	Noticeable peak increase	Greater voltage sensitivity	Multi-objective optimization
40%	High	Significant peak pressure	Increased voltage deviation risk	Network-constrained optimization
50%	Very high	Greater congestion risk	Requires careful voltage management	Multi-objective optimization with smart control

SIGNIFICANCE OF THE TOPIC

Introduction

The increasing adoption of electric vehicles (EVs) is transforming the global transportation and energy sectors. EVs offer an environmentally sustainable alternative to conventional fuel-powered vehicles by reducing dependence on fossil fuels and supporting the transition toward low-carbon transportation. However, the growing demand for EV charging introduces significant challenges for electrical distribution networks, including peak load increases, voltage fluctuations, power losses, and network congestion.

The topic "Multi-Objective Optimization of Electric Vehicle Charging Schedules in Distribution Networks" is significant because it provides an intelligent approach to coordinating EV charging activities while maintaining the economic efficiency, reliability, and stability of electrical distribution systems. By simultaneously optimizing multiple performance objectives, the proposed approach can support the development of smart grids and sustainable energy infrastructure.

Major Significance of the Topic

Reduction in Peak Load Demand

Uncontrolled EV charging can increase electricity demand during peak consumption periods. Multi-objective optimization enables EV charging schedules to be distributed across suitable time intervals, reducing simultaneous charging and minimizing peak demand. This can help prevent transformer overloading and distribution feeder congestion.

Improvement in Voltage Stability

High EV charging demand may cause voltage drops, particularly in distribution network areas with limited power capacity. The proposed optimization framework incorporates voltage constraints and voltage deviation minimization to maintain acceptable voltage levels throughout the network.

Minimization of Distribution Network Power Losses

Electrical power losses increase when excessive current flows through distribution lines. Coordinated EV charging can reduce unnecessary loading and improve power distribution efficiency. This helps distribution system operators utilize existing infrastructure more effectively.

Reduction in Electricity Charging Costs

Electricity tariffs often vary according to demand and time of consumption. Intelligent charging schedules can shift EV charging toward lower-cost periods while satisfying battery energy requirements. This can reduce electricity expenses for EV owners and charging station operators.

Efficient Integration of Renewable Energy Sources

The integration 4of solar and wind energy is essential for sustainable electricity generation. Optimized EV charging can coordinate vehicle charging activities with renewable energy availability, increasing the utilization of locally generated clean electricity and reducing dependence on conventional grid electricity.

Support for Vehicle-to-Grid Technology

Vehicle-to-grid (V2G) technology allows EV batteries to supply electricity back to the distribution network when necessary. Multi-objective optimization can coordinate charging and discharging schedules to support peak demand management, improve energy flexibility, and provide additional grid support.

Enhancement of Distribution Network Reliability

The proposed approach considers important operational constraints, including voltage limits, feeder capacity, transformer loading, battery state of charge, and charging requirements. By maintaining these constraints, optimized charging schedules can reduce network operating stress and support reliable electricity distribution.

Development of Smart Grid Infrastructure

Multi-objective EV charging optimization supports smart grid development through intelligent scheduling, real-time monitoring, automated control, and data-driven decision-making. It can be integrated with advanced metering infrastructure, smart charging stations, and energy management systems.

Economic Benefits for Distribution System Operators

Efficient EV charging management can reduce the need for immediate distribution infrastructure upgrades by improving the utilization of existing network capacity. It can also help distribution companies manage demand more effectively and improve operational planning.

Environmental Sustainability

Coordinated charging can improve renewable energy utilization and support the wider adoption of electric mobility. When combined with low-carbon electricity generation, these strategies can contribute to reducing transportation-related emissions and promoting sustainable energy consumption.

Significance for Different Stakeholders

Table 1. Stakeholder-Wise Significance of the Proposed Research

Stakeholders	**Major Benefits**	**Expected Contribution**
EV Owners	Reduced charging expenses	Affordable and convenient charging
Distribution Companies	Better load management	Improved network efficiency
Grid Operators	Reduced peak demand	Enhanced operational reliability
Charging Station Operators	Intelligent charging allocation	Improved charging infrastructure utilization
Renewable Energy Producers	Better coordination with EV demand	Increased renewable energy utilization
Government and Policymakers	Sustainable transportation planning	Support for clean energy policies
Researchers	Advanced optimization frameworks	Further development of smart charging technologies

4. Academic and Research Significance

The proposed research contributes to the development of intelligent optimization techniques for modern electrical distribution systems. It provides opportunities to investigate:

- The application of MOPSO and NSGA-II for multi-objective EV charging optimization.
- The relationship between EV penetration and distribution network performance.
- The integration of renewable energy resources into EV charging schedules.
- The impact of V2G technology on network flexibility and peak demand.
- The development of cost-effective and network-constrained charging strategies.
- The use of artificial intelligence and machine learning for predictive EV charging management.

Furthermore, the study provides a foundation for future research involving decentralized charging coordination, real-time optimization, distributed energy resources, and intelligent energy management systems.

AI Tech International Journal, **ISSN: 3079-4749**
Vol. 4, No. 1, January-June, 2026,
Journal homepage: https://techaijournal.com

LIMITATIONS & DRAWBACKS

Introduction

Although multi-objective optimization of electric vehicle (EV) charging schedules offers several advantages for improving the efficiency, reliability, and sustainability of electrical distribution networks, its implementation involves various technical, economic, computational, and operational challenges. The integration of large numbers of EVs introduces uncertainties in charging demand, battery characteristics, renewable energy availability, and electricity pricing. Furthermore, optimization algorithms such as Genetic Algorithm (GA), Particle Swarm Optimization (PSO), Multi-Objective Particle Swarm Optimization (MOPSO), and Non-Dominated Sorting Genetic Algorithm II (NSGA-II) require appropriate parameter selection and computational resources.

Understanding these limitations is essential for developing practical, scalable, and reliable EV charging management systems.

Major Limitations and Drawbacks

High Computational Complexity

Multi-objective optimization involves simultaneously evaluating several conflicting objectives, including charging costs, peak demand, power losses, and voltage deviations. As the number of EVs, charging stations, and distribution network constraints increases, the optimization problem becomes more computationally demanding.

Large-scale optimization may require substantial processing time, making real-time scheduling difficult, particularly when frequent changes in charging demand occur.

Uncertainty in EV Charging Demand

EV charging demand depends on several unpredictable factors, such as vehicle arrival times, departure times, daily travel distances, and battery state of charge. Variations in user behavior can reduce the accuracy of predetermined charging schedules.

Therefore, optimization models based on fixed charging profiles may not always represent actual operating conditions.

Renewable Energy Generation Uncertainty

Solar and wind energy generation depends on weather conditions, seasonal variations, and environmental factors. Unexpected reductions in renewable generation may affect previously optimized EV charging schedules.

Accurate forecasting and adaptive scheduling mechanisms are required to manage this uncertainty effectively.

Battery Degradation

Frequent charging and discharging, particularly under vehicle-to-grid (V2G) operation, can accelerate battery degradation. Although V2G technology provides flexibility for managing electricity demand, excessive battery cycling may reduce battery capacity and operational lifetime.

Optimization frameworks must therefore incorporate battery degradation costs and charging-cycle limitations.

Voltage and Network Constraints

Distribution networks have limitations associated with bus voltage levels, transformer capacities, feeder thermal ratings, and power flow. High EV penetration may create operational difficulties, particularly in weak distribution networks.

Maintaining all network constraints during optimization can increase model complexity and computational requirements.

Algorithm Parameter Sensitivity

Optimization algorithms are influenced by parameters such as population size, mutation probability, crossover rate, inertia weight, acceleration coefficients, and archive size.
Improper parameter selection may result in:

- Premature convergence.
- Poor solution diversity.
- Slow convergence.
- Inconsistent optimization results.
- Failure to identify high-quality Pareto-optimal solutions.

Difficulty in Selecting the Best Pareto-Optimal Solution
Multi-objective optimization generally produces multiple non-dominated solutions rather than one universally optimal solution. These solutions represent different trade-offs between economic and technical objectives.

For example, a charging schedule that minimizes electricity costs may not provide the lowest power losses or the best voltage profile. Selecting the most appropriate solution requires decision-making methods such as TOPSIS or weighted preference approaches.

Communication and Infrastructure Requirements
Intelligent EV charging requires communication between vehicles, charging stations, distribution system operators, and energy management platforms.
The implementation of these systems may require:

- Smart meters and advanced sensors.
- Reliable communication networks.
- Real-time monitoring infrastructure.
- Automated charging controllers.
- Secure data management systems.

The installation and maintenance of these technologies can increase implementation costs.

Cybersecurity and Data Privacy Risks
Smart charging systems exchange information about vehicle usage, charging schedules, energy consumption, and user behavior. Inadequate cybersecurity mechanisms may expose these systems to unauthorized access, data manipulation, communication attacks, and service disruptions.

Protecting user information and maintaining secure communication are essential for reliable implementation.

Limited Scalability and Generalization
An optimization strategy developed and tested on a standard IEEE 33-bus or 69-bus distribution system may not perform equally well in every practical distribution network.
Differences in network topology, load characteristics, transformer capacity, EV penetration, and charging infrastructure can affect optimization performance. Large-scale real-world applications require additional testing and model adaptation.

Technical and Operational Limitations

Table 1. Technical Limitations of the Proposed Framework

Limitation	Description	Potential Impact
Computational complexity	Multiple objectives and constraints increase processing requirements	Longer optimization time
EV demand uncertainty	Unpredictable arrival and departure patterns	Scheduling inaccuracies
Renewable intermittency	Variable solar and wind generation	Charging schedule instability
Battery degradation	Repeated charging and discharging affect battery health	Reduced battery lifetime
Network constraints	Limited feeder and transformer capacity	Congestion and voltage problems
Parameter sensitivity	Algorithm performance depends on parameter settings	Inconsistent solutions
Pareto solution selection	Multiple non-dominated solutions are generated	Difficult decision-making
Communication limitations	Dependence on reliable data exchange	Operational delays
Cybersecurity threats	Exposure to unauthorized access and attacks	Data and system security risks
Scalability	Performance may vary across network sizes	Implementation difficulties

4. Economic and Implementation Challenges

Table 2. Economic and Practical Drawbacks

Parameters	Challenges	Possible Consequences
Initial investment	High cost of smart charging infrastructure	Financial burden
Communication systems	Installation of advanced communication equipment	Additional expenditure
Smart charging stations	Requirement for intelligent controllers	Increased infrastructure costs

V2G implementation	Bidirectional charger requirements	Higher installation costs
Battery maintenance	Battery degradation and replacement expenses	Increased lifecycle costs
Software development	Need for advanced optimization platforms	Development complexity
System maintenance	Continuous monitoring and technical support	Recurring operational expenses
Regulatory framework	Differences in energy policies and standards	Implementation delays

CONCLUSION

The increasing adoption of electric vehicles (EVs) has created new opportunities for sustainable transportation while introducing significant challenges for electrical distribution networks. The growing demand for EV charging can increase peak electricity consumption, distribution network power losses, voltage deviations, and transformer loading. Therefore, effective coordination and optimization of EV charging schedules are essential for maintaining the reliability, efficiency, and stability of modern power distribution systems. This study on "Multi-Objective Optimization of Electric Vehicle Charging Schedules in Distribution Networks" presents an intelligent optimization framework for addressing these challenges through coordinated EV charging management.

The proposed framework considers multiple conflicting objectives, including minimizing electricity charging costs, reducing active power losses, limiting peak demand, and improving voltage stability. Optimization techniques such as Genetic Algorithm (GA), Particle Swarm Optimization (PSO), Multi-Objective Particle Swarm Optimization (MOPSO), and Non-Dominated Sorting Genetic Algorithm II (NSGA-II) provide suitable approaches for developing efficient charging schedules. By incorporating battery state-of-charge requirements, vehicle arrival and departure times, charging power limits, feeder capacity, and bus voltage constraints, the framework aims to ensure that optimized charging schedules satisfy both user requirements and distribution network operating conditions.

The comparative analysis highlights the limitations of uncontrolled charging and the potential advantages of TOU-based and intelligent multi-objective charging strategies. In particular, MOPSO and NSGA-II can generate Pareto-optimal solutions that enable distribution system operators to balance economic and technical priorities. Furthermore, integrating renewable energy sources, such as solar and wind power, can improve renewable energy utilization, while vehicle-to-grid (V2G) technology can provide additional flexibility for peak demand management and energy balancing.

REFERENCES

1. 1. Acha, S., Green, T. C., & Shah, N. (2010). Effects of optimised plug-in hybrid vehicle charging strategies on electric distribution network losses. In 2009 IEEE PES Transmission and Distribution Conference and Exposition: Smart Solutions for a Changing World. IEEE. https://doi.org/10.1109/TDC.2010.5484387
2. 2. Baran, M. E., & Wu, F. F. (1989). Network reconfiguration in distribution systems for loss reduction and load balancing. IEEE Transactions on Power Delivery, 4(2), 1401–1407. https://doi.org/10.1109/61.25627
3. 3. Bessa, R. J., & Matos, M. A. (2012). Economic and technical management of an aggregation agent for electric vehicles: A literature survey. European Transactions on Electrical Power, 22(3), 334–350.
4. 4. Clement-Nyns, K., Haesen, E., & Driesen, J. (2010). The impact of charging plug-in hybrid electric vehicles on a residential distribution grid. IEEE Transactions on Power Systems, 25(1), 371–380. https://doi.org/10.1109/TPWRS.2009.2036481
5. 5. Coello Coello, C. A. (2006). Evolutionary multi-objective optimization: A historical view of the field. IEEE Computational Intelligence Magazine, 1(1), 28–36. https://doi.org/10.1109/MCI.2006.1597059
6. 6. Deb, K., Pratap, A., Agarwal, S., & Meyarivan, T. (2002). A fast and elitist multiobjective genetic algorithm: NSGA-II. IEEE Transactions on Evolutionary Computation, 6(2), 182–197. https://doi.org/10.1109/4235.996017
7. 7. Deilami, S., Masoum, A. S., Moses, P. S., & Masoum, M. A. S. (2011). Real-time coordination of plug-in electric vehicle charging in smart grids to minimize power losses and improve voltage profile. IEEE Transactions on Smart Grid, 2(3), 456–467. https://doi.org/10.1109/TSG.2011.2159816
8. 8. García-Villalobos, J., Zamora, I., San Martín, J. I., Asensio, F. J., & Aperribay, V. (2014). Plug-in electric vehicles in electric distribution networks: A review of smart charging approaches. Renewable and Sustainable Energy Reviews, 38, 717–731. https://doi.org/10.1016/j.rser.2014.07.040
9. 9. Gan, L., Topcu, U., & Low, S. H. (2013). Optimal decentralized protocol for electric vehicle charging. IEEE Transactions on Power Systems, 28(2), 940–951. https://doi.org/10.1109/TPWRS.2012.2210288
10. 10. Kempton, W., & Tomić, J. (2005). Vehicle-to-grid power fundamentals: Calculating capacity and net revenue. Journal of Power Sources, 144(1), 268–279. https://doi.org/10.1016/j.jpowsour.2004.12.025
11. 11. Kennedy, J., & Eberhart, R. (1995). Particle swarm optimization. In Proceedings of ICNN'95—International Conference on Neural Networks (Vol. 4, pp. 1942–1948). IEEE. https://doi.org/10.1109/ICNN.1995.488968
12. 12. Lopes, J. A. P., Soares, F. J., & Almeida, P. M. R. (2011). Integration of electric vehicles in the electric power system. Proceedings of the IEEE, 99(1), 168–183. https://doi.org/10.1109/JPROC.2010.2066250

13. 13. Lund, H., & Kempton, W. (2008). Integration of renewable energy into the transport and electricity sectors through V2G. Energy Policy, 36(9), 3578–3587. https://doi.org/10.1016/j.enpol.2008.06.007
14. 14. Ma, Z., Callaway, D. S., & Hiskens, I. A. (2013). Decentralized charging control of large populations of plug-in electric vehicles. IEEE Transactions on Control Systems Technology, 21(1), 67–78. https://doi.org/10.1109/TCST.2011.2174059
15. 15. Mets, K., Verschueren, T., Haerick, W., Develder, C., & De Turck, F. (2010). Optimizing smart energy control strategies for plug-in hybrid electric vehicle charging. In 2010 IEEE/IFIP Network Operations and Management Symposium Workshops (pp. 293–299). IEEE.
16. 16. Mwasilu, F., Justo, J. J., Kim, E.-K., Do, T. D., & Jung, J.-W. (2014). Electric vehicles and smart grid interaction: A review on vehicle to grid and renewable energy sources integration. Renewable and Sustainable Energy Reviews, 34, 501–516. https://doi.org/10.1016/j.rser.2014.03.031
17. 17. Nutkani, I., Toole, H., Fernando, N., & Chiang, A. L. P. (2024). Impact of EV charging on electrical distribution network and mitigating solutions—A review. IET Smart Grid, 7(5), 485–502. https://doi.org/10.1049/stg2.12156
18. 18. Richardson, D. B. (2013). Electric vehicles and the electric grid: A review of modeling approaches, impacts, and renewable energy integration. Renewable and Sustainable Energy Reviews, 19, 247–254. https://doi.org/10.1016/j.rser.2012.11.042
19. 19. Saber, A. Y., & Venayagamoorthy, G. K. (2011). Plug-in vehicles and renewable energy sources for cost and emission reductions. IEEE Transactions on Industrial Electronics, 58(4), 1229–1238. https://doi.org/10.1109/TIE.2010.2047828
20. 20. Sortomme, E., Hindi, M. M., MacPherson, S. D. J., & Venkata, S. S. (2011). Coordinated charging of plug-in hybrid electric vehicles to minimize distribution system losses. IEEE Transactions on Smart Grid, 2(1), 198–205. https://doi.org/10.1109/TSG.2010.2090913
21. 21. Sundström, O., & Binding, C. (2012). Flexible charging optimization for electric vehicles considering distribution grid constraints. IEEE Transactions on Smart Grid, 3(1), 26–37.
22. 22. Tan, K. M., Ramachandaramurthy, V. K., & Yong, J. Y. (2016). Integration of electric vehicles in smart grid: A review on vehicle to grid technologies and optimization techniques. Renewable and Sustainable Energy Reviews, 53, 720–732. https://doi.org/10.1016/j.rser.2015.09.012
23. 23. Chandra, I., Singh, N. K., & Samuel, P. (2024). A comprehensive review on coordinated charging of electric vehicles in distribution networks. Journal of Energy Storage, 89, Article 111659. https://doi.org/10.1016/j.est.2024.111659.