AI Tech International Journal, **ISSN: 3079-4749**
Vol. 4, No. 1, January-June, 2026,
Journal homepage: https://techaijournal.com

Optimal Sizing of Solar-Wind-Battery Hybrid Systems for Rural Electrification

Amina Otieno

Dept. of Renewable Energy Engineering, Lake crest Technical University, Kenya

Article Info

Article history:
Received December 24, 2025
Revised January 5, 2026
Accepted January 30, 2026
Published March 02, 2026

Keywords: Solar Photovoltaic (PV), Wind Energy, Battery Storage, Hybrid Renewable Energy System, Rural Electrification.

ABSTRACT

Rural electrification remains a significant challenge in remote and underserved regions due to limited access to conventional grid infrastructure, high transmission costs, and unreliable power supply. Solar–wind–battery hybrid renewable energy systems offer a sustainable and reliable alternative by combining complementary renewable resources with battery energy storage. This study focuses on the optimal sizing of a hybrid solar photovoltaic (PV), wind energy, and battery storage system for rural electrification. The proposed approach determines the appropriate capacities of PV panels, wind turbines, and battery storage to meet the electrical demand while minimizing the overall system cost and maintaining a reliable power supply. Key factors such as renewable resource availability, load demand, battery state of charge, system losses, and reliability constraints are considered in the sizing process. The optimization framework aims to reduce unmet load, excess energy, and dependence on conventional energy sources while improving the utilization of renewable resources. The results demonstrate that an optimally sized solar–wind–battery configuration can provide reliable and cost-effective electricity for rural communities, while reducing dependence on fossil fuels and associated greenhouse-gas emissions. The study highlights the potential of hybrid renewable energy systems as a viable solution for sustainable and decentralized rural electrification.

This is an open access article under the CC BY-SA license.

PROPOSED MODELS AND METHODOLOGIES

For the study "Optimal Sizing of Solar–Wind–Battery Hybrid Systems for Rural Electrification," the following models and methodology can be proposed:

1. Hybrid System Configuration

The proposed system consists of three primary renewable-energy components:
Solar photovoltaic (PV) system for converting solar radiation into electrical energy.
Wind energy conversion system (WECS) for generating electricity from available wind resources.
Battery energy storage system (BESS) for storing surplus renewable energy and supplying power during periods of low solar and wind generation.
The hybrid system is designed to operate as a standalone microgrid capable of meeting the electrical demand of a rural community.

2. Solar PV Model

The output power of the PV system can be estimated from solar irradiance and cell temperature:
PPV=Prated(GGref)[1+α(Tc−Tref)]P_{PV}=P_{rated}\left(\frac{G}{G_{ref}}\right)[1+\alpha(T_c-T_{ref})]
wherePratedP_{rated} is the rated PV capacity, GG is the incident solar irradiance, GrefG_{ref} is reference irradiance, α\alpha is the temperature coefficient, and TcT_c is the cell temperature.

3. Wind Energy Model

Wind turbine output is determined using the turbine power curve. In simplified form:

PW={0,v<vciPratedv3−vci3vr3−vci3,vci≤v<vrPrated,vr≤v≤vco0,v>vcoP_W = \begin{cases} 0, & v<v_{ci} \\ P_{rated}\frac{v^3-v_{ci}^3}{v_r^3-v_{ci}^3}, & v_{ci}\leq v<v_r \\ P_{rated}, &v_r\leq v\leq v_{co} \\ 0, & v>v_{co} \end{cases}

where vv is wind speed, while vciv_{ci}, vrv_r, and vcov_{co} represent cut-in, rated, and cut-out wind speeds, respectively.

4. Battery Storage Model

The battery is modeled using its state of charge (SOC). During charging:

SOCt+1=SOCt+ηcPch,tΔtEBSOC_{t+1}=SOC_t+\frac{\eta_c P_{ch,t}\Delta t}{E_B}

During discharging:

SOCt+1=SOCt−Pdis,tΔtηdEBSOC_{t+1}=SOC_t-\frac{P_{dis,t}\Delta t}{\eta_dE_B}

where EBE_B is the battery capacity and ηc,ηd\eta_c,\eta_d are charging and discharging efficiencies. Battery operation is constrained between specified minimum and maximum SOC limits.

5. Load Demand Model

A representative rural load profile is developed using the expected consumption of households, agricultural activities, schools, health centers, shops, and community facilities. Hourly or sub-hourly load data are used to capture variations in demand throughout the day and across seasons.

6. Energy Management Strategy

At each time interval, the generated renewable power is compared with the load demand:

Renewable generation first supplies the local load.

Surplus energy is used to charge the battery.

When renewable generation is insufficient, the battery supplies the deficit.

If the battery reaches its minimum SOC and renewable generation remains insufficient, the remaining demand is classified as unmet load.

Excess renewable energy that cannot be utilized or stored is considered surplus/curtailed energy.

7. Optimal Sizing Model

The optimization problem determines the optimal capacities of PV, wind turbines, and batteries:

X=[PPV,PW,EB]X=[P_{PV},P_W,E_B]

The objective function can minimize the total annualized system cost (TAC):

min⁡TAC=Ccapital+Creplacement+CO&M+Cbattery+Cpenalty\min

TAC=C_{capital}+C_{replacement}+C_{O\&M}+C_{battery}+C_{penalty}

A penalty term can be included for unmet electrical demand to ensure that economically attractive but unreliable configurations are avoided.

8. Optimization Constraints

The proposed model considers the following constraints:

Power balance between generation, storage, and demand.

PV and wind capacity limits.

Battery SOC limits.

Battery charging/discharging power limits.

Maximum allowable loss of power supply probability (LPSP).

Renewable-energy contribution requirements.

Maximum permissible unmet load.

System reliability and operational constraints.

9. Optimization Algorithm

An optimization technique such as Particle Swarm Optimization (PSO), Genetic Algorithm (GA), Grey Wolf Optimization (GWO), or a hybrid metaheuristic algorithm can be employed to determine the optimal combination of PV, wind, and battery capacities. The algorithm evaluates different system configurations and identifies the configuration that provides the best trade-off between cost, reliability, renewable-energy utilization, and environmental performance.

10. Performance Evaluation

The optimized system is evaluated using key technical and economic indicators, including:

Net Present Cost (NPC)

Levelized Cost of Energy (LCOE)

Renewable Fraction (RF)

Loss of Power Supply Probability (LPSP)
Unmet Load
Excess Energy
Battery utilization and SOC profile
CO_2 emission reduction
Annual renewable energy generation

Overall, the proposed methodology provides a systematic framework for determining the minimum-cost and reliable solar–wind–battery configuration capable of satisfying rural electricity demand under variable renewable-resource conditions.

RESULTS & ANALYSIS

The proposed solar–wind–battery hybrid system is evaluated in terms of energy performance, reliability, economic feasibility, and renewable-energy utilization. The optimization results indicate that combining solar and wind resources with battery storage provides a more reliable electricity supply than relying on a single renewable source.

1. Optimal System Configuration

The optimization process determines the appropriate capacities of the PV array, wind turbine, and battery bank based on the rural load profile and available renewable resources. The optimal configuration should satisfy the electricity demand while minimizing the total annualized cost. In general, the hybrid configuration reduces the need for excessive battery capacity because solar and wind generation complement each other during different periods of the day and year.

2. Renewable Energy Generation

Solar PV generally contributes a significant proportion of the annual energy generation, particularly during daytime hours. Wind energy complements solar generation during periods of reduced solar availability, including nighttime and some seasonal periods. The combination therefore improves the overall utilization of renewable resources and reduces periods of energy deficiency.

3. Battery Performance

The battery storage system plays a critical role in balancing generation and demand. During periods of excess solar or wind generation, the battery is charged, while stored energy is discharged when renewable generation is insufficient. The optimized battery capacity prevents excessive curtailment while maintaining an adequate state of charge for periods of low renewable generation.

4. Reliability Analysis

System reliability is evaluated using Loss of Power Supply Probability (LPSP) and unmet electrical load. The optimized system is expected to achieve a low LPSP while maintaining sufficient energy availability for critical rural loads. Compared with a solar-only or wind-only configuration, the hybrid system provides greater reliability because the two renewable resources partially compensate for each other's variability.

5. Economic Analysis

The economic performance is assessed using Net Present Cost (NPC) and Levelized Cost of Energy (LCOE). Although incorporating three components increases the initial investment, the hybrid system can reduce long-term operating costs by increasing renewable-energy utilization and decreasing dependence on diesel generators or grid electricity. Battery replacement and operation-and-maintenance costs are also included in the economic assessment.

6. Environmental Benefits

The proposed system significantly reduces dependence on fossil-fuel-based electricity. Consequently, greenhouse-gas emissions associated with rural electricity generation can be reduced. Higher renewable-energy penetration also improves the sustainability of the electrification scheme and supports decentralized clean-energy development.

7. Comparative Analysis

A representative comparison can be presented as follows:

Configuration	Reliability	Battery Requirement	Renewable Utilization	Expected Cost
Solar + Battery	Moderate–High	High	High	Moderate
Wind + Battery	Moderate	High	Moderate	Moderate
Solar + Wind	Moderate	Low	High	Moderate
Solar + Wind + Battery	High	Optimized	Very High	Optimized

The analysis indicates that the solar–wind–battery configuration provides the best overall balance between reliability, renewable-energy utilization, and economic performance. The battery compensates for short-term fluctuations and periods of renewable-energy shortage, while the complementary nature of solar and wind resources reduces the required storage capacity.

8. Overall Findings

The results demonstrate that optimal sizing is essential because an oversized system increases capital expenditure and produces excess energy, whereas an undersized system leads to greater unmet load and reduced reliability. The proposed optimization methodology identifies a balanced configuration that can meet rural electricity demand with high renewable penetration and acceptable economic performance. Therefore, solar–wind–battery hybrid systems represent a technically feasible and environmentally sustainable approach for decentralized rural electrification.

Note: The numerical values for NPC, LCOE, LPSP, renewable fraction, PV capacity, wind capacity, and battery capacity should be inserted after running the proposed model with the actual rural load, solar irradiance, wind-speed, and component-cost data. The above results are therefore suitable as a qualitative/results-section framework rather than fabricated experimental measurements.

COMPARATIVE ANALYSIS

The following table provides a comparative analysis of different configurations for rural electrification. The values are presented as representative/illustrative results and should be replaced with simulation results from the proposed model.

Parameter	Solar PV + Battery	Wind + Battery	Solar + Wind	Solar + Wind + Battery
Renewable sources	Solar	Wind	Solar + Wind	Solar + Wind
Battery storage	Required	Required	Not mandatory	Optimized
System reliability	Moderate–High	Moderate	Moderate	High
Renewable utilization	High	Moderate	High	Very High
Power availability	Daytime dominant	Wind dependent	Variable	More consistent
Excess energy	Moderate	Moderate	High	Low–Moderate
Unmet load	Moderate	Moderate–High	Moderate	Low
Battery dependency	High	High	Low	Moderate
Initial investment	Moderate	Moderate	High	High
Operating cost	Low	Low	Low	Low
LPSP	Higher	Higher	Moderate	Lowest
Environmental impact	Low	Low	Very low	Very low
Overall performance	Good	Fair	Very good	Excellent

Summary of Comparison

The comparison shows that the Solar–Wind–Battery Hybrid System provides the most balanced solution for rural electrification. While its initial investment may be higher than single-source alternatives, the combination of complementary solar and wind resources with battery storage improves system reliability, renewable-energy utilization, and power availability, while reducing unmet load and dependence on conventional energy sources.

For a research paper, the table can be followed by the statement:

"The comparative analysis demonstrates that the proposed solar–wind–battery hybrid configuration offers superior overall performance compared with individual renewable-energy configurations. The integration of battery storage improves system reliability by compensating for the intermittent nature of solar and wind resources, while the complementary generation characteristics of both renewable sources reduce unmet load and excess energy. Hence, the proposed hybrid configuration is considered a suitable and sustainable option for reliable rural electrification."

Significance of the Topic

The study "Optimal Sizing of Solar–Wind–Battery Hybrid Systems for Rural Electrification" is significant because reliable access to electricity is essential for improving the socio-economic development and quality of life of rural communities. Many remote areas face challenges such as limited grid connectivity, high electricity transmission costs, unreliable power supply, and dependence on fossil-fuel-based generation. Renewable-energy-based hybrid systems provide an opportunity to address these challenges through decentralized and sustainable electricity generation.

The major significance of the study includes:

Reliable Rural Electrification: Combining solar and wind energy with battery storage can provide a more continuous and reliable electricity supply despite the intermittent nature of renewable resources.

Optimal Utilization of Renewable Resources: Solar and wind resources complement each other. Proper sizing allows available renewable energy to be utilized effectively while minimizing excess generation.

Reduction in System Cost: Optimal sizing avoids unnecessary investment in oversized PV panels, wind turbines, and batteries while maintaining the required reliability.

Energy Storage Integration: Battery storage helps balance the mismatch between renewable generation and electricity demand, particularly during nighttime, cloudy periods, or low-wind conditions.

Environmental Sustainability: The proposed system can reduce dependence on diesel generators and conventional fossil-fuel-based electricity, thereby lowering greenhouse-gas emissions and local pollution.

Improved Energy Access: Decentralized hybrid systems can supply electricity to remote communities where extending conventional transmission and distribution networks may be technically difficult or economically impractical.

Economic and Social Development: Reliable electricity can support schools, healthcare centers, agricultural activities, small businesses, communication facilities, and household applications, contributing to improved rural livelihoods.

Support for Sustainable Development: The study contributes to the broader goals of clean energy, energy security, climate-change mitigation, and sustainable rural development.

Overall Significance
The significance of this research lies in developing an economically viable, technically reliable, and environmentally sustainable approach to rural electrification. By determining the optimal combination of solar PV, wind generation, and battery storage, the study can help minimize system cost while maximizing renewable-energy utilization and electricity reliability. This makes the proposed hybrid system a promising solution for future decentralized energy systems in remote and underserved regions.

LIMITATIONS & DRAWBACKS

Although solar–wind–battery hybrid systems provide a promising solution for rural electrification, several limitations and drawbacks need to be considered:

High Initial Investment: The installation of PV panels, wind turbines, batteries, inverters, and control equipment requires significant upfront capital.

Intermittent Renewable Resources: Solar and wind generation depends strongly on weather and seasonal conditions. Variations in solar irradiance and wind speed can affect power availability.

Battery Degradation: Batteries lose storage capacity with repeated charging and discharging. Their limited lifetime increases replacement and maintenance costs.

Complex System Optimization: Determining the optimal combination and capacity of PV, wind, and battery components requires detailed resource assessment, load forecasting, and optimization techniques.

Dependence on Accurate Data: The reliability of the sizing results depends on the availability and accuracy of solar radiation, wind-speed, temperature, and electricity-demand data.

Excess Energy Generation: During periods of high renewable generation and low demand, surplus electricity may be produced. Without sufficient storage or suitable loads, this energy may be curtailed.

Maintenance Requirements: Wind turbines contain mechanical components that may require regular inspection and maintenance. Battery systems and power-electronic equipment also require appropriate servicing.

Environmental and Land Considerations: Large PV arrays and wind turbines require land and appropriate site selection. Wind turbines may also create concerns related to visual impact, noise, and effects on local ecosystems.

Battery Disposal and Environmental Concerns: End-of-life batteries require proper recycling and disposal to prevent environmental contamination and recover valuable materials.

Limited Applicability of Simulation Results: Results obtained for one rural location may not be directly applicable to another region because renewable-resource availability, load patterns, costs, and climatic conditions vary geographically.

Grid-Integration Challenges: If the hybrid system is later connected to the main grid, additional requirements related to synchronization, protection, power quality, and regulatory standards may arise.

Overall Limitation
The major limitation is the trade-off between cost, reliability, and renewable-energy availability. Increasing PV, wind, or battery capacity can improve reliability but may also increase capital expenditure and system complexity. Therefore, accurate resource assessment, realistic load modeling, appropriate component selection, and robust optimization are essential for achieving a practical and economically feasible hybrid system.

CONCLUSION

The study on "Optimal Sizing of Solar–Wind–Battery Hybrid Systems for Rural Electrification" demonstrates the potential of hybrid renewable-energy systems as a reliable, economical, and environmentally sustainable solution for providing electricity to remote and underserved communities. The integration of solar PV, wind energy, and battery storage effectively addresses the intermittent nature of individual renewable sources and improves the continuity of power supply.

The proposed optimization methodology enables the appropriate sizing of PV capacity, wind generation, and battery storage while considering load demand, renewable-resource availability, system reliability, and economic constraints. The comparative analysis indicates that the combined solar–wind–battery configuration offers better overall performance than single-source renewable systems by reducing unmet load, improving renewable-energy utilization, and providing greater energy reliability.

Although the system involves relatively high initial investment and depends on accurate renewable-resource and load data, its long-term benefits include reduced dependence on fossil fuels, lower greenhouse-gas emissions, improved energy access, and enhanced rural socio-economic development. Battery degradation, renewable-resource variability, maintenance requirements, and system complexity remain important challenges that must be addressed during practical implementation.

Overall, optimal sizing of solar–wind–battery hybrid systems can provide a technically feasible and sustainable approach to decentralized rural electrification. Future work may focus on advanced optimization algorithms, real-time energy management, improved battery technologies, demand-side management, and integration of emerging storage technologies to further improve system reliability and economic performance.

REFERENCES

1. Below are 25 references in APA 7th style that are relevant to your research topic, *"Optimal Sizing of Solar–Wind–Battery Hybrid Systems for Rural Electrification."* I have prioritized research on hybrid renewable-energy systems, optimal sizing, battery storage, rural electrification, LPSP, techno-economic analysis, and optimization algorithms. ScienceDirect+2
2. Anand, P., Rizwan, M., & Bath, S. K. (2019). Sizing of renewable energy based hybrid system for rural electrification using grey wolf optimisation approach. *IET Energy Systems Integration*. https://doi.org/10.1049/iet-esi.2018.0053 IET
3. Al-Ghussain, L., & Taylan, O. (2019). An investigation of optimum PV and wind energy system capacities for alternate short and long-term energy storage sizing methodologies. *International Journal of Energy Research*. https://doi.org/10.1002/er.4251 DOI
4. Alturki, F. A., Al-Shamma'a, A. A., Farh, H. M. H., &AlSharabi, K. (2021). Optimal sizing of autonomous hybrid energy system using supply-demand-based optimization algorithm. *International Journal of Energy Research, 45*, 605–625. https://doi.org/10.1002/er.5766 DOI
5. Bhandari, B., Lee, K.-T., Lee, C.-S., Song, C.-K., Maskey, R. K., &Ahn, S.-H. (2014). A novel off-grid hybrid power system comprised of solar photovoltaic, wind, and hydro energy sources. *Applied Energy, 133*, 236–242. https://doi.org/10.1016/j.apenergy.2014.07.033 DOI
6. Borowy, B. S., &Salameh, Z. M. (1996). Methodology for optimally sizing the combination of a battery bank and PV array in a wind/PV hybrid system. *IEEE Transactions on Energy Conversion, 11*(2), 367–375.
7. Chedid, R., Akiki, H., & Rahman, S. (1997). A decision support technique for the design of hybrid solar-wind power systems. *IEEE Transactions on Energy Conversion, 13*(1), 76–83.
8. Demolli, H., &Dokuz, A. S. (2021). Location-based optimal sizing of hybrid renewable energy systems using deterministic and heuristic algorithms. *International Journal of Energy Research*. https://doi.org/10.1002/er.6849 DOI
9. Dursun, B., &Aykut, E. (2019). An investigation on wind/PV/fuel cell/battery hybrid renewable energy system for nursing home in Istanbul. *Proceedings of the Institution of Mechanical Engineers, Part A: Journal of Power and Energy, 233*(5), 616–625. https://doi.org/10.1177/0957650919840519 DOI

10. Hakimi, S. M., &Moghaddas-Tafreshi, S. M. (2009). Optimal sizing of a stand-alone hybrid power system via particle swarm optimization for Kahnouj area in south-east of Iran. *Renewable Energy, 34*(7), 1855–1862. https://doi.org/10.1016/j.renene.2008.11.022 ScienceDirect
11. Hocaoglu, F. O., Gerek, Ö. N., &Kurban, M. (2009). A novel hybrid (wind–photovoltaic) system sizing procedure. *Solar Energy, 83*(11), 2019–2028.
12. Koutroulis, E., Kolokotsa, D., Potirakis, A., &Kalaitzakis, K. (2006). Methodology for optimal sizing of stand-alone photovoltaic/wind-generator systems using genetic algorithms. *Solar Energy, 80*(9), 1072–1088. https://doi.org/10.1016/j.solener.2005.11.002 ScienceDirect
13. Krishnamoorthy, M., Periyanayagam, A. D. V. R., Kumar, C. S., Kumar, B. P., Srinivasan, S., &Kathiravan, P. (2022). Optimal sizing, selection, and techno-economic analysis of battery storage for PV/BG-based hybrid rural electrification system. *IETE Journal of Research, 68*(6), 4061–4076. https://doi.org/10.1080/03772063.2020.1787239 Taylor & Francis Online
14. Mathew, S., et al. (2022). Sizing approaches for solar photovoltaic-based microgrids: A comprehensive review. *IET Energy Systems Integration*. https://doi.org/10.1049/esi2.12048 DOI
15. Mohammed, A., et al. (2024). Optimal sizing of hybrid renewable energy system using two-stage stochastic programming. *International Journal of Energy Research*. https://doi.org/10.1155/2024/2361858 DOI
16. Mishra, J., & Shankar, A. (2025). Optimizing wind-PV-battery microgrids for sustainable and resilient residential communities. *Scientific Reports, 15*, 24339. https://doi.org/10.1038/s41598-025-06354-6 DOI
17. Murugaperumal, K., &Vimal Raj, P. A. D. (2019). Feasibility design and techno-economic analysis of hybrid renewable energy system for rural electrification. *Solar Energy*. https://doi.org/10.1016/j.solener.2019.07.008 ScienceDirect
18. Murugaperumal, K., &Vimal Raj, P. A. D. (2019). Techno-economic analysis of a hybrid renewable energy system for an energy poor rural community. *Journal of Energy Storage, 23*, 305–319. https://doi.org/10.1016/j.est.2019.04.002 ScienceDirect
19. Prasad, A. R., & Natarajan, E. (2006). Optimization of integrated photovoltaic-wind power generation systems with battery storage. *Energy, 31*(12), 1949–1960.
20. Sahu, P. K., Jena, S., & Sahoo, U. (2021). Techno-economic analysis of hybrid renewable energy system with energy storage for rural electrification. In *Hybrid renewable energy systems*. Wiley. https://doi.org/10.1002/9781119555667.ch3 Wiley Online Library